

Ichigo Preserves and Improves Real Estate



[Provisional Translation Only]

This English translation of the original Japanese document is provided solely for information purposes. Should there be any discrepancies between this translation and the Japanese original, the latter shall prevail.

October 5, 2016

Ichigo Inc. (Tokyo Stock Exchange First Section, 2337)

Representative: Scott Callon, Chairman

Inquiries: Takeyuki Yoshimatsu, Executive Managing Director

Telephone: +81-3-3502-4818 en.ichigo.gr.jp/english

Ichigo Solar Power Generation and CO₂ Reduction Data – September 2016

FY16/2				
	Power Generation (kWh)	CO ₂ Reduction (kg-CO ₂) ¹		
March	3,203,083	2,114,035		
April	3,474,152	2,292,940		
May	4,122,044	2,720,549		
June	3,663,109	2,417,652		
July	4,083,889	2,695,367		
August	3,812,172	2,516,033		
H1	22,358,452	14,756,578		
September	3,658,084	2,414,335		
October	4,111,990	2,713,913		
November	2,501,232	1,650,813		
December	2,681,709	1,769,928		
January	2,539,683	1,676,190		
February	3,493,432	2,305,655		
H2	18,986,132	12,530,846		
Full Year	41,344,585	27,287,425		

FY17/2				
	Power Generation (kWh)	CO ₂ Reduction (kg-CO ₂) ¹	Year-on- Year Change	
March	5,024,560	3,316,209	+56.9%	
April	5,056,266	3,337,135	+45.5%	
May	5,949,535	3,926,692	+44.3%	
June	4,881,431	3,221,744	+33.3%	
July	6,160,967	4,066,238	+50.9%	
August	6,255,441	4,128,591	+64.1%	
H1	33,328,202	21,996,612	+49.1%	
September	4,273,439	2,820,470	+16.8%	
October	_			
November				
December				
January	_	_	_	
February	_	_	_	
H2	_	_		
Full Year	_	_	_	

Explanation

Power generation in September was 4,273,439kWh, a 1.2X increase year-on-year, but 15% below the P50 power production forecast of 5,016,000kWh due to a significant decrease in productive daylight hours in eastern and western Japan and Okinawa and a moderate decrease in northern Japan.² The P50 forecast for October is 4,892,000kWh, with the Ichigo Hamanaka Bokujo Kajibayashi ECO Power Plant beginning operation this month.

Detailed production data for each Ichigo solar power plant is available on the website of Ichigo ECO Energy: www.ichigo.gr.jp/eco/english

¹ CO₂ reduction is calculated as 0.66kg CO₂ per kWh.

² P50 is a third-party, 50% probability mean annual production forecast that serves as the base forecast for each solar power plant's operating plan.